



**Fire Underwriters Survey**

A SERVICE TO INSURERS AND MUNICIPALITIES

c/o Opta Information Intelligence

October 9<sup>th</sup>, 2024

**RECOGNITION FOR FIRE INSURANCE GRADING RECEIVED**

*Niagara West Fire & Emergency Services*

**Superior Tanker Shuttle Service - Accredited**

I am pleased to advise you that the above-mentioned fire protection district within the province of Ontario was recently registered in the fire insurance grading index as being accredited for the delivery of Superior Tanker Shuttle Service.

The requirements for this accreditation are stringent and verify that the fire protection district is capable of delivering the minimum accepted fire flows to detached dwellings throughout the fire protection district and within 8 kilometres by road of the below accredited Fire Station. An application towards Commercial Lines (PFPC) insurance has also been achieved by exceeding the 400 IGPM PFPC flow rate requirements. This accreditation is an equivalency to the minimum requirements for hydrant protection, as set out by the insurance industry and the Fire Underwriters Survey.

Fire Underwriters Survey has provided information on fire protection and risk levels to the insurance industry in Canada since 1883. Fire Underwriters Survey was previously operated under the auspices of the Insurers Advisory Organization and CGI; however, is now operated by Opta Information Intelligence.

Should you have any questions or concerns related to the Fire Underwriters Survey, the Superior Tanker Shuttle Service Accreditation process, or any other related area, please contact the offices of Fire Underwriters Survey for further information.

Please note that this accreditation expires on October 4<sup>th</sup>, 2029 and is valid for the following fire station:

- Lincoln – Fire Station #1 – 4594 Ontario St., Beamsville, Lincoln, ON L0R 1B3
- Lincoln – Fire Station #2 – 3970 Fly Rd., Campden, Lincoln, ON L0R 1G0
- Lincoln – Fire Station #4 – 3793 Nineteenth St., Jordan Station, Lincoln, ON L0R 1S0

Personal Lines Fire Insurance Classification – DPG 3B(S) – Flow Rate of 203 IGPM

Commercial Lines Fire Insurance Classification – PFPC 6(S) – Flow Rate of 520 IGPM

Mark Radejewsky, C.Tech  
Fire Protection Specialist  
Fire Underwriters Survey



**British Columbia:**

800 665 5661

**Ontario:**

877 642 4468

**Québec:**

877 640 8352

**Atlantic Canada:**

877 634 8564

POWERED BY   
[optaintel.ca](http://optaintel.ca)  
[fireunderwriters.ca](http://fireunderwriters.ca)